

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**  
**CERTIFICATE.**

No. DWTG FZR/072/2023-24.

Date: 09/01/2023

It is certified that an inspection team headed by Harpreet Singh  
Lab Chemist, Distt Water Testing Laboratory Ferozepur (Name of Officers  
with designation) from Water Supply & Sanitation Deptt, FZR (Name of  
Department/Office) inspected the S.S.M. Global School  
Kassoana, Block-Zira, Distt-Ferozepur (Name & Address of  
the School) on 08-02-2023 and found that the S.S.M. Global  
School (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T. Govt.

09/01/2023 to 08/01/2024.

The above valid for a period of One year i.e

Signature with Seal Harpreet Singh  
Name : Harpreet Singh  
Designation : Lab Chemist  
Lab Chemist/J.E. Incharge  
Distt. Water Testing Laboratory  
W/s & Sanitation Deptt.  
Ferozepur

To

The principal  
S.S.M. Global School  
Kassoana, Block-Zira, Distt-Ferozepur.

(Name & Address of the Institution)



Daul  
Principal  
S.S.M. Global School  
Kassoana (FZR)

**WATER SUPPLY & SANITATION DISTRICT LEVEL WATER TESTING  
LABORATORY  
ANALYSIS REPORT OF WATER SAMPLES**

**Particulars of Samples**

	Sample No. 1	Sample No. 2	<u>Date of Receipt</u>	<u>Date of Conducting</u>
1 Place/Name of Village	S.S.M. Global School, Kassoana.		02/02/22	02/02/22
2 Block/District	Zira / Feroze pur			
3 Source	Submersible Bore			
4 Date and time of collection	02-03-2022			
5 Depth	7.50'			
6 Spring Level	-			
7 Name and designation of the Person collecting the sample	S. Kanwaljit Singh (Principal)			


**TEST RESULTS**

**PHYSICAL AND CHEMICAL**

1 Turbidity (JTU)	-	
2 Colour (Units on Pt-Co Scale)	-	
3 Taste and odors (Qualitative)	-	
4 PH	7.2	
5 Total Dissolved Solids mg/l	348	
6 Total Alkalinity (as CaCo3) mg/l	164	
7 Hardness (as CaCo3)mg/l		
(a) Total	118	
(b) Calcium	20	
(c) Magnesium	-	
(d) Carbonate	-	
(e) Non-Carbonate	-	

P.T.O.

  
**MANAGER**  
**S.S.M. GLOBAL SCHOOL**  
**KASSOANA (FZR.)**

  
**Principal**  
**S.S.M. Global School**  
**Kassoana (Fzr)**

8 Chloridés (as/Cl) mg/l	...34.....	.....
9 Sulphates (as So4) mg/l	.....	.....
10 Fluorides (as F) mg/l	...0.25.....	.....
11 Nitrate (as No.3) mg/l	.....	.....
12 Iron (as Fe.) mg/l	.....	.....
13 Residual Chlorine (as Cl) mg/l	.....	.....
14 Conductivity micromhos/cm	.....	.....

**BACTERIOLOGICAL**

- 1 Plate Count (colonies/ml) /
- 2 Caliform Organisms (MPN/100 ml) /

Remarks : (In view of the above analysis)


Sample No : 1

- The water is potable / not potable
- ~~2 The following parameters are more than the acceptable, but less than the cause for rejection limit~~

Sample No : 2

- 1 The water is potable / not potable.
- 2 The following parameters are more than the acceptable, but less than the cause for rejection limit

ATTESTED

  
**Lab Chemist/J.E. Incharge**  
**Distt. Water Testing Laboratory**  
**W.S.S. & Sanitation Deptt.**  
**Ferozepur.**

SAMPLE CONSUMED IN TESTING

  
**MANAGER**  
**S.S.M. GLOBAL SCHOOL**  
**KASSOANA (FZR.)**

  
**Principal**  
**S.S.M. Global School**  
**Kassoana (Fzr)**